

Annual Drinking Water Quality Report for 2010
Village of Mohawk
28 Columbia St., Mohawk, NY 13407
(Public Water Supply ID# NY2102310)

INTRODUCTION

To comply with State and Federal regulations, the **Village of Mohawk**, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system has never violated a maximum contaminant level or any other water quality statement. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact, **Andrew Steele, Public Utilities Foreperson, at (315) 868-4170**. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled Municipal Commission meetings. **The meetings are held at the Village Hall located at 28 Columbia Street, Mohawk, NY.**

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source is a groundwater source consisting of two drilled wells, that for the purpose of this report shall be referred to as Well #2 and Well #3. Well #2 was developed in 1969; it is 18 inches in diameter and is 52 feet deep. Well # 2 produces about 1150 gallons per minute. Well #3 was developed in 1990 and is also 18 inches in diameter and is 60 feet deep. Well #3 produces about 750 gallons per minute. The water is chlorinated with a sodium hypochlorite solution as it is pumped from the wells, prior to distribution the water now passes through a Ultraviolet Disinfection system, water that is not consumed by our customers is stored in two 500,000 gallon concrete storage tanks. Our water system serves a population of 2983 through 952 service connections.

SOURCE WATER ASSESSMENT SUMMARY

The source water assessment summary for the Village of Mohawk was not yet available from the New York State Department of Health at the time this report was completed. Questions regarding the source water assessment should be directed to the New York State Department of Health – Herkimer District Office (315) 866-6879.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Herkimer Falls District Office- Herkimer County Health Department at (315) 866-6879.

Table of Detected Contaminants

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Average) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Inorganics							
Copper #2	No	7/17/08	0.17 .050- 1.1	Mg/l	1.3	AL=1.3	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives
Selenium	No	7/27/07	1.3	ug/l	50	50	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Lead #3	No	7/17/08	4.8 ND – 6.0	ug/l	0	AL= 15	Corrosion of household plumbing systems; Erosion of natural deposits.
Nitrate	No	9/10/10	2.54	Mg/l	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Barium	No	9/10/10	0.209	Mg/l	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural
Chromium	No	9/10/10	4.1	ug/l	100	100	Discharge from steel and pulp mills; Erosion of natural deposits.

Organic Compounds							
Bis-(2-Ethylhexyl) Adipate	No	12/29/10	61	Ug/l	N/A	50	Discharge from chemical factories
Disinfection By-Products							
Total Trihalomethanes	No	7/10/09	4.90	MG/L	80	80	By-product of drinking water chlorination needed to kill harmful organisms, TTHMs are formed when source water contains large amounts of organic matter.
Haloacetic Acids (HAA5)	No	7/10/09	1.2	Ug/l	0	60	By-product of drinking water chlorination needed to kill harmful organisms, TTHMs are formed when source water contains large amounts of organic matter
Chlorine Residual	No	Daily	.48 .40 - .70	MG/L	0	4.0	By-product of drinking water chlorination needed to kill harmful organisms
Radiological Contaminants							
Gross Beta	No	4/01	4.E 0+/- 2.E	PC/L	0	15	Decay of natural deposits and man-made emissions.
Gross Alpha Radon	No	9/10	<3.0 +/- 2.1 525.3	PC/L	0	15	Erosion of natural deposits.
Radium 228	No	9/10	<1.0 +/- 0.12	pCi/L	0	5	Decay of natural deposits and man-made emissions.

Notes:

#2 – The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 10 samples were collected at your water system and the 90th percentile value was the 0.17 mg/l value. The action level for copper was not exceeded at any of the sites tested.

#3 – The level presented represents the 90th percentile of the 10 samples collected. The action level for lead was not exceeded at any of the 10 sites tested.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

Millirems per year (mrem/yr): A measure of radiation absorbed by the body.

WHAT DOES THIS INFORMATION MEAN?

We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2009 our system was not in violation of State drinking water requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the **Safe Drinking Water Hotline (800-426-4791)**.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- ◆ Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, Then check the meter after 15 minutes, If it moved, you have a leak.

Closing

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. **Please call our office if you have questions at (315) 866-4170.**